



Government Of West Bengal
Office Of The Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services
Ghoshpara Road, P.O.:- Bengal Enamel, Pin :- 743122

Memo no.:FSR/0125186211100805

Date: 16-12-2023

From:
Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services

To: MORNING BELLS ACADEMY
310 EAST GHOSH PARA ROAD SHYAMNAGAR. NORTH 24 PGS -743127

Sub: Fire Safety Certificate for occupancy of an existing B+G+IV storied under group Educational Building in the name & Style of 'MORNING BELLS ACADEMY' at premises No. 310 EAST GHOSH PARA ROAD, SHYAMNAGAR, NORTH 24 PGS -743127.

This is in reference to your application no. 0125189211100398 dated 02-12-2023 regarding the Fire Safety Certificate for occupancy of an existing B+G+IV storied under group Educational Building in the name & Style of 'MORNING BELLS ACADEMY' at premises No. 310 EAST GHOSH PARA ROAD, SHYAMNAGAR, NORTH 24 PGS -743127.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

1. Fire License shall have to be obtained for proposed storing and processing with L.P.G. and other highly combustible articles.
2. The Interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the Building.
5. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
6. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building..
7. A crew of trained Fireman shall be maintained round the clock for safety of the building.
8. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
9. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189211100398.

Page : 1

10. Pump should be kept in such a order that it would be operated manually and also automatically through D.G. Set. when normal power failure.
11. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Periodical flashing of water from the Hydrants and Sprinkler Pipe line shall be made to maintain the efficient working performance of above mentioned system.
13. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
14. This F.S.C. is valid for three years and have to be renewed every after three years from the date of issue of this letter.
15. Every after three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, performance of all the life & Fire Safety arrangements and installation of the buildings.
16. Any deviation / Changes the building in respect of approved plan drawing without prior permission from this office , this Fire Safety Certificate will be treated as cancelled.

Signature valid

Digitally signed by DEBTANU
BASU
Date: 2023.12.16 12:28:24 IST

Divisional Fire Officer, North 24 Parganas
West Bengal Fire & Emergency Services